

Our Ref: NOC-97196/MATERIAL/SN25736/12-HB

Date: 08 April, 2012

M/s ALL ASPECTS

P. O. Box 39613
Sharjah, U.A.E

Attention: **Mr. Karim Hanna**

E-mail: aaaim@eim.ae

Phone: 06-5569913

Subject: **MATERIAL REVIEW REPORT**
Turboseal P & Turboseal U

Dear Sir,

With reference to your technical submission dated 20 March, 2012 (Submission No. 25763); please note that we have **No Objection** on using Turbo-Seal P and Turbo-Seal U as a waterproofing material subject to the following conditions.

- To strictly comply with manufacturer technical recommendations.
- Applicator of the waterproofing system should be approved by the manufacturer.
- Not to use the waterproofing materials in water tanks and planters.
- A Guarantee letter of minimum 15 years should be awarded to every executed project.
- This No Objection is valid for one year from the date of this letter.

Yours faithfully,

HUSSEIN KHALIL BASMA
SENIOR MANAGER – QUALITY CONTROL
TRAKHEES - PORTS, CUSTOMS & FREE ZONE CORP.